

REVO-IP REV-D EMERGENCY Instructions

Remove the end cap to access the AC connections.



When clipping the end cap into position ensure that the AC and red/black LED indicator cables are located away from the sealing ring to ensure a correct fit.

At the other end remove the end cap, unclip the battery assembly and slide out.



Clip together the battery connectors, carefully re-insert the battery assembly and refit the end cap.

For more information on the REVO-IP REV-D series or help with installation, please visit: www.powerled.uk.com or call 0118 970 3856.